



गुप्त भो/ 20/24/82

दिनांक 29/3/24

Sub: Approval of fire fighting scheme from the fire safety point of view of the Education Building (B) Named M/S Govt. Model Sanskriti Senior Secondary School, Village Khewra Distt Sonipat.

M/s Govt. Model Sanskriti Senior Secondary School, Village Khewra Distt Sonipat. has submitted the subject cited case for Approval of Fire Fighting Scheme from fire safety point of view of **Education Building (B)** through transaction ID-181312423000147 **Dated- 21/03/2024** The office has examined the Fire Fighting Scheme in the drawing of above said building and found that the building is an **Education Building (B)** Fire fighting scheme shown in the Building Plans are found as per provision of Part-IV of National Building Code of India, 1983 revised from time to time and Haryana Fire & Emergency Services Act, 2022. The fire system designed **Education Building (B)** as per Part- IV of NBC 2016, is as under:-

Building Detail :-

1. Name of Building :- **Govt. Model Sanskriti Senior Secondary School,**
2. Address of building :- **Village Khewra Distt Sonipat.**
3. Plot Area. :- 17649.57 Sqm
4. Type of Occupancy :- Education Building (B)
5. Permissible Height :- 15 Mtr
6. Basement Detail- :- Nil

Tower No. / Name	Basement Level	Basement Area	Remarks
Nil	Nil	Nil	-

Tower/Block Detail:-

Tower No. / Block	Floor Area (Ground Coverage)	No. of Floor	Occupied Height	Stair Case		
				Min per NBC	As per Travel Distance	Provide d
Block A	1812.73 Sqm	GF+1	7.62 Mtr	Yes	Less then 30 Mtr	Yes 2 Nos
Block B	266.51 Sqm	GF+1	7.62 Mtr	Yes	Less then 30 Mtr	Yes 2 Nos
Block C	351.80 Sqm	GF	4.20 Mtr	N/R	N/A	N/A
Block D	95.02 Sqm	GF	4.20 Mtr	N/R	N/A	N/A
Block E	30.57 Sqm	GF	4.20 Mtr	N/R	N/A	N/A
Block F	77.72 Sqm	GF	4.20 Mtr	N/R	N/A	N/A
Block G	73.71 Sqm	GF	4.20 Mtr	N/R	N/A	N/A
Block H	17.96 Sqm	GF	4.20 Mtr	N/R	N/A	N/A

Fire Fighting System Detail-

S.N.	Norms as per NBC, 2016	Required	Proposed provisions



Principal

GOVT. SR. SEC. SCHOOL

Khewra, Sonapat - 131001 (Haryana)
School Code : 3626

Ref. No.

Dated... 23/11/2024

To

Director of Fire Service,
Haryana, Bay No, 55-58, 2nd floor
Sector-2, Panchkula.

Sub:- Regarding issue Fire Safety Certificate (NOC)

R/sin

The matter cited above as per vide order no 24/19-2021 Act (I) dated 5/11/23 from DSE Haryana Panchkula, our school is G.M.S.S.S School Khewra applied for CBSE affiliation. As per CBSE guidelines, the fire safety certificate (NOC) is very essential. So please issue the fire safety certificate (NOC) from your department as soon as possible.

D.A

1. Fire Certificate & HAP, Questionnaire
2. Architect Declaration
3. Departmental letter and other documents and apply online and certificate from Sonapat office

Sunder W

Principal
Govt Sr Sec School
KHEWRA (3626)
Sonapat